







## Vibration Monitoring Data - Monthly Summary

Month and Year	February 2020	 
Project	Sydenham Metro upgrade	
EPL Licence No.	21147	
EPL Weblink	<a href="https://apps.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=21147&amp;id=21147&amp;option=licence&amp;searchrange=licence&amp;range=POEO%20licence&amp;prp=no&amp;status=issued">https://apps.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=21147&amp;id=21147&amp;option=licence&amp;searchrange=licence&amp;range=POEO%20licence&amp;prp=no&amp;status=issued</a>	
Specific EPL monitoring conditions	M7.2 - Vibration monitoring	

Monitoring Location	Number of times monitored during the month	Attended or continuous monitoring	Event based monitoring (Y/N)	Parameter eg.PPV	Unit	Minimum value for month	Maximum value for month	Goals/Targets	Comment
Platform 2/3 Station Building - City End	1	Continuous	Y	PPV	mm/s	0.271	1.2	7.5	Single event during demolition of building 1 - completed over 3 hours. Real time run before and after demolition to attain baseline