

Noise Monitoring Data - Monthly Summary

Month and Year	September 2019								
Project	Sydenham Metro upgrade								
EPL Licence No.	21147								
EPL Weblink	https://apps.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=21147&id=21147&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued								
Specific EPL monitoring conditions	M7.1 - Noise monitoring								
Monitoring Location	Number of times monitored during the month	Attended or continuous monitoring	Event based monitoring (Y/N)	Parameter eg. Laeq (15min)	Unit	Min value dB(A) for month	Max value dB(A) for month	Goals / targets dB(A)	Comment
Railway Road	1	Attended	Y	Laeq	dB(A)	59	59	64	Compliant
Railway Road	1	Attended	Y	Laeq	dB(A)	51.4	51.4	70	Compliant



JOHN HOLLAND

Vibration Monitoring Data - Monthly Summary

Month and Year	September 2019	 
Project	Sydenham Metro upgrade	
EPL Licence No.	21147	
EPL Weblink	https://apps.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=21147&id=21147&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=issued	
Specific EPL monitoring conditions	M7.2 - Vibration monitoring	

Monitoring Location	Number of times monitored during the month	Attended or continuous monitoring	Event based monitoring (Y/N)	Parameter eg.PPV	Unit	Minimum value for month	Maximum value for month	Goals/Targets	Comment
Sydenham Pit	1	Continuous	Y	PPV	mm/s	0.2	0.5	7.5	Compliant
Geotech Building	1	Continuous	Y	PPV	mm/s	0.1	0.95	7.5	Compliant