

Noise Monitoring Data - Monthly Summary

Month and Year	June 2021	 
Project	Sydenham Metro upgrade	
EPL Licence No.	21147	
EPL Weblink	https://apps.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=21147&id=21147&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued	
Specific EPL monitoring conditions	M7.1 - Noise monitoring	

Monitoring Location	Number of times monitored during the month	Attended or continuous monitoring	Event based monitoring (Y/N)	Parameter eg. Laeq (15min)	Unit	Min value dB(A) for month	Max value dB(A) for month	Goals / targets dB(A)	Comment
360 Edgeware Rd, Newtown	1	Attended	Y	Laeq	dB(A)	63	63	66	WE52 - piling at Bedwind Rd
30 Hogan Ave, Sydenham	1	Attended	Y	Laeq	dB(A)	56	56	63	WE52 - installation of corridor gate
14A Ernest St, Lakemba	1	Attended	Y	Laeq	dB(A)	56	56	65	June/July Shutdown - RW21
20 Loftus St, Belmore	1	Attended	Y	Laeq	dB(A)	59	59	69	June/July Shutdown - Trackworks Belmore
28 Sth Parade, Campsie	1	Attended	Y	Laeq	dB(A)	56	56	66	June/July Shutdown - Trackworks Campsie
35 Sth Parade, Campsie	1	Attended	Y	Laeq	dB(A)	61	61	69	June/July Shutdown - Trackworks Campsie

Vibration Monitoring Data - Monthly Summary

Month and Year	June 2021								
Project	Sydenham Metro upgrade								
EPL Licence No.	21147								
EPL Weblink	https://apps.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=21147&id=21147&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued								
Specific EPL monitoring conditions	M7.2 - Vibration monitoring								
Monitoring Location	Number of times monitored during the month	Attended or continuous monitoring	Event based monitoring (Y/N)	Parameter eg.PPV	Unit	Minimum value for month	Maximum value for month	Goals/Targets	Comment
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

