



Water Monitoring Data - Monthly Summary

Month and Year	September 2021	 
Project	Sydenham Metro upgrade	
EPL Licence No.	21147	
EPL Weblink	https://apps.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=21147&id=21147&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=issued	
Specific EPL monitoring conditions	M2 - Requirement to monitor concentration of pollutants discharged	

Monitoring Location	Number of times monitored during the month	Event based monitoring (Y/N)	Parameter eg. TSS, pH	Unit eg mg/L	Minimum value for month	Maximum value for month	Allowable Maximum limit	Allowable Minimum limit	Comment
Discharge Point 2	1	Y	pH	pH	8.06	8.06	8.5	6.5	
Discharge Point 2	1	Y	TSS	mg/L	20	20	50	-	
Discharge Point 2	1	Y	Oil/grease	Visible	None visible	None visible	None visible	None visible	N/A

Noise Monitoring Data - Monthly Summary

Month and Year	September 2021								
Project	Sydenham Metro upgrade								
EPL Licence No.	21147								
EPL Weblink	https://apps.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=21147&id=21147&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued								
Specific EPL monitoring conditions	M7.1 - Noise monitoring								
Monitoring Location	Number of times monitored during the month	Attended or continuous monitoring	Event based monitoring (Y/N)	Parameter eg. Laeq (15min)	Unit	Min value dB(A) for month	Max value dB(A) for month	Goals / targets dB(A)	Comment
360 Edgeware Rd, Newtown	2	Attended	Y	Laeq	dB(A)	65	67	77	Linemarking works
30 Hogan Avenue, Sydenham	1	Attended	Y	Laeq	dB(A)	65	65	83	Power outage works
136 George St, Sydenham	1	Attended	Y	Laeq	dB(A)	77	77	78	Power outage works



